


# New FLOW MONITOR Replaceable Flow Vane type



### **Visibility**

Fluid flow from low flow rate (2 L/min) can be visually checked with the rotating two-colored impeller.

# **Easy maintenance**

Flow Vane ASSY can be replaced without removing it from the piping (both models).


# **Safety**

The stopper prevents unintended removal of the plastic parts.

## **Easy installation**

The installation and replacement is easy since the screw part of T2 side rotates freely to the left and right.






Model		FMC-30-3F	FMC-30-4F
Size (Thread)		Rc 3/8	Rc 1/2
Body material		Brass	
Flow Vane ASSY material (Plastic part)	Outer cylinder	Polycarbonate	
	Impeller	Polypropylene	
	Inner sleeve, Stopper	Polyamide	
Working pressu	re +1	1.0 MPa, 10 kgf/cm <sup>2</sup> , 10 bar, 145 PSI	
Working flow ra	inge	2 to 20 L/min	
Seal material (N	lark)	Fluoro rubber (FKM)	
Working temper	ature range ·2	+10°C to +80°C	
Mass		167 g	256 g

Flow Direction	
Fluid flow can be bi-directional.	

<b>Maximum Tightening To</b>	Nm {kgf•cm}	
Size (Thread)	Rc 3/8	Rc 1/2
Torque	12 {122}	30 {306}

Models and Dime	ensions			
	Rc 3/8		Rc 3/8	
Model FMC-30-3F	930			
	Hex.23 Rc 1/2	(81)	Hex.21	
Model FMC-30-4F	032			
	Hex.29	(94)	Hex.29	(mm)



FM-03-B

Rc 3/8

Brass

Polycarbonate

0.5 MPa, 5 kgf/cm², 5 bar, 72.5 PSI 5 to 18 L/min

> Nitrile rubber (NBR) +10°C to +60°C

> > 190 g

11 {112}

For low pressure



Water

# For stable and accurate coolant flow rate.

Size (Thread)

**Body material** 

**Graduated tube material** 

Working temperature range -2

**Maximum Tightening Torque** 

Working pressure 1

Working flow range Seal material (Mark)

Model

# FLOW METER

#### **CUPLA** related product / Flow meter with special valve



Fluid must flow in the direction of the arrows.

\*Plastic part (graduated tube) cannot be replaced. This product is not "CUPLA".

### **▲** Safety Guide

Read without fail and observe the "Instruction sheet" that comes with the product and the following pages in the Quick Connect Couplings General Catalog; [Precautions Relating to the Use of All CUPLA].

- \*1: The normal allowable fluid pressure under continuous use.

  Continuously exceeding the working pressure may cause leakage or damage.
- \*2: The working temperature range depends upon the operating conditions.

NITTO KOHKI CO., LTD.

#### **Head Office**

9-4, Nakaikegami 2-chome, Ohta-ku, Tokyo 146-8555, Japan Tel : +81-3-3755-1111 Fax : +81-3-3753-8791

E-mail: overseas@nitto-kohki.co.jp



Nm {kgf • cm}

Web www.nitto-kohki.co.jp/e/

**DISTRIBUTED BY**